

NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Richmond County Water System Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Monitoring results for water samples collected during the time period ending September 30, 2017 show that the contaminant concentration from one or more sampling locations in our water system exceeds the standard, or maximum contaminant level (MCL), for TOTAL TRIHALOMETHANES (TTHMs). The standard for TTHMs is 0.080 milligrams per liter (mg/L). Over the referenced compliance period, the sample location with the highest average level of TOTAL TRIHALOMETHANES had a concentration of 0.083 mg/l.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, *some people who drink the water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.*

What happened? What is being done? When will the problem be corrected?

The Richmond County Water System has implemented several corrective actions that have been effective and returned the TTHM level in all areas of the system below the standard. Those include: reduced chlorine usage, regular flushing of system water lines and close monitoring of water tank levels.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact:

Responsible Person Lee P. Butler	System Name Richmond County Water System	System Address (Street) 326 Old Charlotte Hwy.
Phone Number 910-997-8339	System PWSID # NC0377109	Rockingham, N.C. 28380

Violation Awareness Date: July 20, 2017

Date Notice Distributed: August 8, 2017

Method of Distribution: Online posting

Public Notification Certification:

The public water system named above hereby affirms that public notification has been provided to its consumer in accordance with all delivery, content, format, and deadline requirements specified in 15A NCAC 18C .1523.

Owner/Operator: _____

(Signature)

Bryan R. Land

(Print Name)

9/20/2017

(Date)